

# *Sampling Protocol for Drinking Water in Schools*



*A Guidance Document for  
Drinking Water Testing*



❖ Schools must use an Illinois Environmental Protection Agency (IEPA) accredited laboratory for the testing.

❖ Schools must provide the Illinois Department of Public Health (IDPH) with sample results within 7 days of receipt. Results should be emailed to [DPH.LeadH2O@illinois.gov](mailto:DPH.LeadH2O@illinois.gov).

**SB 0550** was signed by Governor Bruce Rauner on January 16, 2017. It requires all schools (Pre-K through 5th grade) to test for lead in water used for drinking and cooking. Schools built after January 1, 2000 are not required to test at this time.

**Sampling must be completed by:**

- ❖ December 31, 2017 — Schools constructed prior to January 1, 1987
- ❖ December 31, 2018 — Schools constructed between January 2, 1987 and January 1, 2000



# *Action Steps Prior to Sampling*

---

1. Your local water supply can be a great resource. Contact them to request assistance in establishing your sampling plan.
2. Obtain a general floor plan for each school building. Floor plans are available in the schools' asbestos management plan.
3. Identify all fixtures to be sampled on the general floor plan. All plumbing fixtures that are used for cooking or drinking must be sampled. Bathroom and utility sinks do not need to be sampled.
4. Assign a unique alphanumeric identifier to each fixture.
5. Label fixture identifiers on the floor plan. Make sure all samples are labeled with the corresponding alphanumeric identifier for each fixture.
6. Determine which IEPA accredited laboratory you will utilize for the analysis. A list can be found at <http://www.epa.illinois.gov/citizens/citizens-information/in-your-home/resources-on-lead/index>.
7. Contact the laboratory to obtain enough 250 mL sample bottles and Chain of Custody forms to allow you to collect 2 samples from each fixture. The laboratory will also provide sample shipping instructions.



# Sample Collection Procedure

## PROCEDURE

- ❖ Do NOT collect samples on Mondays or after extended holiday/break periods.
- ❖ Schools should develop a program to routinely flush plumbing fixtures after extended school closings.
- ❖ Do NOT flush plumbing fixtures in advance of sampling.

1. Each fixture must be sampled twice:
  - a. First draw sample
  - b. Second draw sample after 30 seconds
2. Ensure water has been idle and unused in pipes and fixtures for at least eight hours, but not more than 18 hours.
3. Prior to sampling, label the sample bottles with the alphanumeric identifier. Do not open the sample bottles until you are ready to collect each sample.
4. Position the first sample bottle beneath the fixture and turn the water on. Do not allow any water to spill.
5. Fill the bottle to the shoulder or the line marked 250 mL and turn the water off. Cap the bottle tightly.
6. Turn the water back on and allow the water to run for 30 seconds before filling the second sample bottle. Cap the bottle tightly.
7. Make sure both bottles are labeled with the date and time, alphanumeric identifier, and sample description (first or second draw).
8. Fill out Chain of Custody for each sample.
9. Continue sampling all fixtures until all samples are collected. Prepare the samples for shipping per laboratory instructions.



**WARNING!** Use caution when collecting samples. Some sample containers may contain a nitric acid preservative that can cause skin irritation.

McHenry Analytical Laboratories, Inc.  
4314-A Crystal Lake Rd. Phone # 815-344-4034  
McHenry, IL 60050 Fax # 815-344-2208 State where samples collected: Illinois

### CHAIN OF CUSTODY RECORD

Client: North Park Public Schools  
Address: 1111 First St  
City: Urbana  
State: Illinois  
Sample ID: 10/15/15  
Sample Description: Water

NO.	DATE	TIME	INITIALS	REMARKS
1	10/15/15	8:00	JK	1st Draw
2	10/15/15	8:30	JK	2nd Draw
3	10/15/15	9:00	JK	1st Draw
4	10/15/15	9:30	JK	2nd Draw
5	10/15/15	10:00	JK	1st Draw
6	10/15/15	10:30	JK	2nd Draw
7	10/15/15	11:00	JK	1st Draw
8	10/15/15	11:30	JK	2nd Draw
9	10/15/15	12:00	JK	1st Draw
10	10/15/15	12:30	JK	2nd Draw

Signature: JK  
Title: Analyst  
Date: 10/15/15

Signature: JK  
Title: Analyst  
Date: 10/15/15

## Test Results

### How to interpret your test results

1. Test results will be reported in either parts per billion (ppb) or micrograms per liter (ug/l). Both units of measure are appropriate.
2. If any sample exceeds 5 ppb of lead, the notification requirements are triggered.



## Reporting and Notification Requirements

- ❖ Within 7 business days of receipt of test results, schools must email all results to IDPH at [DPH.LeadH2O@illinois.gov](mailto:DPH.LeadH2O@illinois.gov).
- ❖ If all sample results are less than 5 ppb, schools may use their website (at minimum) to notify parents of the results.
- ❖ If any of the sample results exceed 5 ppb, schools must notify parents in writing or electronically, and include :
  - The location and source exceeding 5 ppb, and
  - The USEPA website for information about lead in drinking water: <https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>.

**Parents should be advised to contact their health care provider with any concerns about their child's health, including blood tests for lead exposure.**

# Next Steps

Test results will likely generate questions from parents, guardians, and the public about steps the school is taking to address lead in water.

Removing fixtures from use may not be an immediate option. Establishment of a water management plan, including identification of lead-containing plumbing, scheduled flushing, fixture replacement, and monitoring is the best course of action for schools addressing positive lead test results.

Additional guidance for interim (short-term) and permanent lead control measures is provided in the USEPA 3Ts for Reducing Lead in Drinking Water in Schools. This document can be found at:

[www.epa.gov/sites/production/files/201509/documents/toolkit\\_leadschools\\_guide\\_3ts\\_leadschools.pdf](http://www.epa.gov/sites/production/files/201509/documents/toolkit_leadschools_guide_3ts_leadschools.pdf)



The Illinois Department of Public Health supports the efforts of Illinois Section AWWA to educate schools about lead testing. For additional information see [dph.illinois.gov](http://dph.illinois.gov).

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Center Cass School Dist 66

**Report Date:** March 13, 2017

**Project Name:** Elizabeth IDE School Drinking Water Lead Analysis

**Workorder:** 1702A29

**Analyte:** Lead

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1702A29-001A	Drinking Fountain 2nd Grade 1	ND	2.00	µg/L	02/03/17 21:00	2/4/2017	2/20/2017
1702A29-002A	Drinking Fountain 2nd Grade 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-003A	Drinking Fountain IMC 1	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-004A	Drinking Fountain IMC 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-005A	Kitchen Sink 1	2.39	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-006A	Kitchen Sink 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-007A	Drinking Fountain 1st Grade 1	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-008A	Drinking Fountain 1st Grade 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-009A	Main Teachers Lounge Sink 1	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-010A	Main Teachers Lounge Sink 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-011A	Nurses Office Sink 1	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-012A	Nurses Office Sink 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-013A	Teachers Lounge Work Mens Room 1	9.86	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-014A	Teachers Lounge Work Mens Room 2	3.07	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-015A	Teachers Sink 2nd Grade 1	2.96	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-016A	Teachers Sink 2nd Grade 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-017A	Teachers Sink 1st Grade 1	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-018A	Teachers Sink 1st Grade 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-019A	Teachers Lounge Work Womens Room 1	379	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-020A	Teachers Lounge Work Womens Room 2	8.98	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-021A	Custodian Sink 1st Grade 1	4.96	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017
1702A29-022A	Custodian Sink 1st Grade 2	ND	2.00	µg/L	02/03/17 21:00	2/14/2017	2/20/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Center Cass School Dist 66

**Report Date:** March 13, 2017

**Project Name:** Prairieview School Drinking Water Lead Analysis

**Workorder:** 1702A35

**Analyte:** Lead

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1702A35-001A	Teachers Lounge 5th Grade 1	ND	2.00	µg/L	02/03/17 20:00	2/4/2017	2/20/2017
1702A35-002A	Teachers Lounge 5th Grade 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-003A	Drinking Fountain 5th Grade 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-004A	Drinking Fountain 5th Grade 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-005A	5th Grade Faculty Bathroom 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-006A	5th Grade Faculty Bathroom 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-007A	4th Grade Faculty Bathroom 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-008A	4th Grade Faculty Bathroom 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-009A	Drinking Fountain 4th Grade 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-010A	Drinking Fountain 4th Grade 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-011A	Teachers Lounge 4th Grade 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-012A	Teachers Lounge 4th Grade 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-013A	2nd Floor Common Drinking Fountain 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-014A	2nd Floor Common Drinking Fountain 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-015A	Drinking Fountain 3rd Grade 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-016A	Drinking Fountain 3rd Grade 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-017A	Teachers Lounge 3rd 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-018A	Teachers Lounge 3rd 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-019A	IMC Office 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-020A	IMC Office 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-021A	Drinking Fountain 1st Floor Hall 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-022A	Drinking Fountain 1st Floor Hall 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-023A	Drinking Fountain MP Room 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-024A	Drinking Fountain MP Room 2	ND	5.00	µg/L	02/03/17 20:00	2/14/2017	2/22/2017
1702A35-025A	Drinking Fountain in Gym 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-026A	Drinking Fountain in Gym 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)



# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134

Tel. (708) 544-3260 • Toll Free (800) 783-LABS

Fax (708) 544-8587

www.suburbanlabs.com

**Client ID:** Center Cass School Dist 66

**Report Date:** March 13, 2017

**Project Name:** Prairieview School Drinking Water Lead Analysis

**Workorder:** 1702A35

**Analyte:** Lead

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1702A35-027A	Dish Washing Sink 1	2.77	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-028A	Dish Washing Sink 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-029A	Fruit Washing Sink 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-030A	Fruit Washing Sink 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-031A	Food Prep Sink 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-032A	Food Prep Sink 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-033A	Nurse Office 1	ND	5.00	µg/L	02/03/17 20:00	2/14/2017	2/22/2017
1702A35-034A	Nurse Office 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-035A	Office Copy Room Sink 1	2.09	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-036A	Office Copy Room Sink 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-037A	District Office Bathroom 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-038A	District Office Bathroom 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-039A	BACC Room Sink 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-040A	BACC Room Sink 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-041A	Main Teachers Lounge Sink 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-042A	Main Teachers Lounge Sink 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-043A	Music Room Drinking Fountain 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-044A	Music Room Drinking Fountain 2	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-045A	Art Room Faucet 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017
1702A35-046A	Art Room Faucet 1	ND	2.00	µg/L	02/03/17 20:00	2/14/2017	2/20/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Center Cass School Dist 66

**Report Date:** March 13, 2017

**Project Name:** Lakeview School Drinking Water Lead Analysis

**Workorder:** 1702A36

**Analyte:** Lead

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1702A36-001A	Drinking Fountain-Music Hall #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-002A	Drinking Fountain Music Hall #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-003A	nking Fountain Music Hall #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-004A	Drinking Fountain Music Hall #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-005A	Drinking Fountain Room 14 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-006A	Drinking Fountain Room 14 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-007A	Sink Room 14 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-008A	Sink Room 14 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-009A	Sink #1 Room 13 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-010A	Sink #1 Room 13 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-011A	Sink #2 Room 13 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-012A	Sink #2 Room 13 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-013A	Sink #3 Room 13 #1	3.38	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-014A	Sink #3 Room 13 #2	2.11	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-015A	Sink #4 Room 13 #1	2.68	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-016A	Sink #4 Room 13 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-017A	Sink #5 Room 13 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-018A	Sink #5 Room 13 #2	2.24	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-019A	Sink #6 Room 13 #1	10.6	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-020A	Sink #6 Room 13 #2	35.0	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-021A	Sink #7 Room 13 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-022A	Sink #7 Room 13 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-023A	Sink #8 Room 13 #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-024A	Sink #8 Room 13 #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-025A	Kitchen Sink #1	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-026A	Kitchen Sink #2	ND	2.00	µg/L	02/06/17 19:00	2/7/2017	2/20/2017
1702A36-027A	Health Office Sink #1	3.53	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-028A	Health Office Sink #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-029A	Faculty Office Sink #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-030A	Faculty Office Sink #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-031A	Lobby Women Drinking Fountain #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-032A	Lobby Women Drinking Fountain #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-033A	Lobby Mens Drinking Fountain #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)

# SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134  
Tel. (708) 544-3260 • Toll Free (800) 783-LABS  
Fax (708) 544-8587  
www.suburbanlabs.com

**Client ID:** Center Cass School Dist 66

**Report Date:** March 13, 2017

**Project Name:** Lakeview School Drinking Water Lead Analysis

**Workorder:** 1702A36

**Analyte:** Lead

**Matrix:** Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1702A36-034A	Lobby Mens Drinking Fountain #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-035A	Teachers Lounge Sink #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-036A	Teachers Lounge Sink #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-037A	Hallway Drinking Fountain #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-038A	Hallway Drinking Fountain #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-039A	Women Drinking Fountain Gym 1 #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-040A	Women Drinking Fountain Gym 1 #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-041A	Men Drinking Fountain Gym 1 #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-042A	Men Drinking Fountain Gym 1 #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-043A	Drinking Fountain #1 Gym 2 #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-044A	Drinking Fountain #1 Gym 2 #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-045A	Drinking Fountain #2 Gym 2 #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-046A	Drinking Fountain #2 Gym 2 #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-047A	Faculty Washroom DE #1	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017
1702A36-048A	Faculty Washroom DE #2	ND	2.00	µg/L	02/06/17 19:00	2/8/2017	2/20/2017

ND - Not Detected Down to the Laboratory Minimum Reporting Limit (MRL)